Review of new SBMS 1.5.0 And NRTL



OBJECTIVES:

Review

- New SBMS standard, 1.5.0, Appendix VIII
- Basic Quadrants
- The "Royal" exception
- Motor Control Centers Controls
- Getting Plugged In
- Personnel Protective Clothing & Equipment
- Precautions



BNL LESC has reviewed the hazards of activities listed in the NFPA 70E table and has revised the hazard levels.


This is listed in the revised SBMS 1.5.0, Appendix VIII

This is based on the footnotes to the tables.


If the device to be operated has a sticker listing Hazard / Risk Category and required PPE,

utilize the Hazard / Risk Category and the PPE listed











Equipment Rating





Equipment Rating



Brookhaven Science Associates U.S. Department of Energy



Equipment Rating







- **220V**
- **30A**













- 480V
- 60A










- **208V**
- 600A












480V 60A Switch 800A Royal



Brookhaven Science Associates U.S. Department of Energy









- 480V
- 30A Switch
- 600A MCC














Receptacles

125V, 30A or less 250V, 30A or less No PPE required

All the rest follow the switching rules.











Hazard Category 0+

All clothing shall be non-melting fabric

Long sleeve shirt

Long pants

Leather gloves (leather palm only are acceptable)

Safety glasses with side shields



■ Hazard Category 2 (8 cal/cm²)

All clothing shall be non-melting fabric and have equivalent rating of 8 cal/cm²

Long sleeve shirt, long pants, & undergarments

Leather gloves

Safety glasses with side shields

Face shield with hardhat (8 cal/cm²)

Leather shoes/sneakers

Hearing protection



Hazard Category 4 (40 cal/cm²)

All clothing shall be non-melting fabric and have equivalent rating of 40 cal/cm²

Multi-layer flash suit with hardhat and hood

Long sleeve shirt, long pants, & undergarments

Leather gloves

Safety glasses with side shields

Leather shoes/sneakers

Hearing protection



- Considerations
- Switches and breakers should not be operated if obviously damaged
- Operate with covers closed and secured
- Line cords, plugs, receptacles shall be inspected for signs of damage
- Turn off equipment before connecting or disconnecting
- If the receptacle has a local switch, it shall be utilized



Voltage Rated Gloves

- Class 00
 Rated for 500 Vac
 Red or Yellow
 (Beige Label)
- Class 2
 Rated for 15,000 Vac
 Red/Black or Yellow/Black
 (Yellow Label)









Brookhaven Science Associates U.S. Department of Energy



- Voltage Rated Gloves (cont.)
 - Must wear leather protector (for specified voltage)
 - Gap between leather and cuff of glove
 - Keep gap clear
 - Test and inspect before each use
 - Exchanged every 6 months



National Electrical Code –NFPA 70

- Article 110
 - Paragraph 110.2 Approval. The conductors and equipment required or permitted by this *Code* shall be acceptable only if approved.
- Definitions
 - Approved. Acceptable to the authority having jurisdiction.
 - Authority Having Jurisdiction. The organization, office, or individual responsible for approving equipment, materials, an installation, or a procedure.
- Article 110
 - Paragraph 110.3 Examination, Identification, installation and use of Equipment of Equipment. (8 steps for examination) but in Article 90- Introduction- Paragraph 90.7- Examination of equipment for safety- acceptable if done by organization that does inspections.



- OSHA
- Welcome to the Nationally Recognized Testing Laboratory (NRTL) Program, which is a part of OSHA's Directorate of Science, Technology, and Medicine. The Program recognizes private sector organizations as NRTLs, and recognition signifies that an organization has met the necessary qualifications specified in the regulations for the Program. The NRTL determines that specific equipment and materials ("products") meet consensus-based standards of safety to provide the assurance, required by OSHA, that these products are safe for use in the U.S. workplace.



- Organizations Currently Recognized By OSHA as NRTLs:
- Applied Research Laboratories, Inc. (ARL)
- Canadian Standards Association (CSA) (also known as CSA International)
- Communication Certification Laboratory, Inc. (CCL)
- Curtis-Straus LLC (CSL)
- Electrical Reliability Services, Inc. (ERS)
 (also known as eti Conformity Services and formerly Electro-Test, Inc. (ETI))
- Entela, Inc. (ENT)
- FM Global Technologies LLC (FM)

 (also known as FM Approvals and formerly Factory Mutual Research Corporation)
- Intertek Testing Services NA, Inc. (ITSNA) (formerly ETL)
- MET Laboratories, Inc. (MET)
- NSF International (NSF)
- National Technical Systems, Inc. (NTS)
- SGS U.S. Testing Company, Inc. (SGSUS) (formerly UST-CA)
- Southwest Research Institute (SWRI)
- TUV America, Inc. (TUVAM)
- TUV Product Services GmbH (TUVPSG)
- TUV Rheinland of North America, Inc. (TUV)
- Underwriters Laboratories Inc. (UL)
- Wyle Laboratories, Inc. (WL)



Does OSHA accept the "CE" mark or accept equipment certified by foreign testing organizations?

The CE mark is unrelated to the requirements for product safety in the US. It is a generic mark used in the European Union (EU) to indicate that a manufacturer has declared that the product meets requirements in the EU for product safety. In the US, under OSHA's NRTL requirements, the product must have the specific mark of one of the NRTLs recognized to test and certify these types of products.

